



דוח שח + קוטש

עבור: קניון הנגב מיזוג אויר צילרים על הגג

קבוצת עזריאלי בע"מ מיזוג אויר צילרים על הגג

תקופת דוח: (31/05/16 - 01/05/16)

תאריך הפקה: 03/06/16


מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	סה"כ ש"ח	שיא ביקוש
1	8851	יטא 19 AC	14154689 - 11	2,093.50	531.90	391.10	3,016.50	1,318.45	6.19
			סה"כ	2,093.50	531.90	391.10	3,016.50	1,318.45	
2	8852	יטא 20 AC	14154689 - 12	593.90	138.40	103.00	835.30	366.61	12.17
			סה"כ	593.90	138.40	103.00	835.30	366.61	
3	8853	יטא 21 AC	14154689 - 13	1,676.90	643.80	330.40	2,651.10	1,146.61	5.28
			סה"כ	1,676.90	643.80	330.40	2,651.10	1,146.61	
4	8854	יטא 22 AC	14154689 - 14	2,128.90	809.80	502.20	3,440.90	1,479.20	4.28
			סה"כ	2,128.90	809.80	502.20	3,440.90	1,479.20	
5	8855	יטא 23 AC	14154688 - 13	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	
6	8856	יטא ac1	14154688 - 1	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	
7	8857	יטא ac10	14154688 - 10	3,685.20	1,139.70	655.30	5,480.20	2,389.72	6.76
			סה"כ	3,685.20	1,139.70	655.30	5,480.20	2,389.72	
8	8858	יטא ac11	14154689 - 1	1,151.10	361.00	207.10	1,719.20	749.18	4.52
			סה"כ	1,151.10	361.00	207.10	1,719.20	749.18	
9	8859	יטא ac12	14154689 - 2	1,217.60	401.00	231.60	1,850.20	803.94	2.36
			סה"כ	1,217.60	401.00	231.60	1,850.20	803.94	
10	8860	יטא ac13	14154689 - 3	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	
11	8861	יטא ac14	14154689 - 4	6,041.80	2,055.00	1,131.00	9,227.80	4,008.86	14.10
			סה"כ	6,041.80	2,055.00	1,131.00	9,227.80	4,008.86	
12	8862	יטא ac15	14154689 - 5	1,764.60	673.60	2,043.00	4,481.20	1,747.23	2.94
			סה"כ	1,764.60	673.60	2,043.00	4,481.20	1,747.23	
13	8863	יטא ac16	14154689 - 6	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	
14	8864	יטא ac17	14154689 - 7	1,314.40	452.00	305.80	2,072.20	893.17	2.87
			סה"כ	1,314.40	452.00	305.80	2,072.20	893.17	






מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	סה"כ ש"ח	שיא ביקוש
15	8865	יטא ac18 פורק	14154689 - 8	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	
16	8866	יטא ac2	14154688 - 2	372.10	124.10	72.10	568.30	246.72	0.56
			סה"כ	372.10	124.10	72.10	568.30	246.72	
17	8867	יטא ac27	14154689 - 9	5,085.40	1,461.00	839.80	7,386.20	3,233.44	11.07
			סה"כ	5,085.40	1,461.00	839.80	7,386.20	3,233.44	
18	8868	יטא ac3	14154688 - 3	34.10	7.00	42.20	83.30	32.28	0.35
			סה"כ	34.10	7.00	42.20	83.30	32.28	
19	8869	יטא ac4	14154688 - 4	429.60	132.90	85.60	648.10	281.54	2.05
			סה"כ	429.60	132.90	85.60	648.10	281.54	
20	8870	יטא ac5	14154688 - 5	7.50	2.80	9.40	19.70	7.63	0.02
			סה"כ	7.50	2.80	9.40	19.70	7.63	
21	8871	יטא ac6	14154688 - 6	652.00	223.00	244.10	1,119.10	472.13	1.78
			סה"כ	652.00	223.00	244.10	1,119.10	472.13	
22	8872	יטא ac7	14154688 - 7	1,633.60	522.50	290.30	2,446.40	1,066.03	4.32
			סה"כ	1,633.60	522.50	290.30	2,446.40	1,066.03	
23	8873	יטא ac8	14154688 - 8	13,703.30	4,469.20	2,496.30	20,668.80	8,995.50	20.83
			סה"כ	13,703.30	4,469.20	2,496.30	20,668.80	8,995.50	
24	8875	יטא ac9	14154688 - 9	1,374.20	492.30	292.80	2,159.30	932.90	4.57
			סה"כ	1,374.20	492.30	292.80	2,159.30	932.90	
25	8876	מגדל קירור 1+2	14154689 - 10	11,220.80	3,440.80	3,956.80	18,618.40	7,892.11	19.54
			סה"כ	11,220.80	3,440.80	3,956.80	18,618.40	7,892.11	
26	8877	מגדל קירור מס 3	14154688 - 12	10,263.60	4,002.00	12,245.20	26,510.80	10,311.30	18.58
			סה"כ	10,263.60	4,002.00	12,245.20	26,510.80	10,311.30	
27	8878	מגדל קירור מס 4	14154688 - 11	15,803.60	5,814.20	17,093.60	38,711.40	15,177.89	20.10
			סה"כ	15,803.60	5,814.20	17,093.60	38,711.40	15,177.89	
			סה"כ	82,247.70	27,898.00	43,568.70	153,714.40	63,552.45	





■ פסגה (Kwh 82,247.70)
■ גבע (Kwh 27,898.00)
■ שפל (Kwh 43,568.70)



■ פסגה (שח 38,722.22)
■ גבע (שח 10,896.96)
■ שפל (שח 13,933.27)

