



דוח שח + קוטש

עבור: קניון הנגב מיזוג אויר צילרים על הגג

קבוצת עזריאלי בע"מ מיזוג אויר צילרים על הגג

תקופת דוח: (30/09/16 - 01/09/16)

תאריך הפקה: 20/11/16


מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטש	תשלום קבוע	סה"כ ש"ח	שיא ביקוש
1	8851	יטא 19 AC	14154689 - 11	2,269.30	591.60	300.80	3,161.70	0.00	1,395.66	5.69
			סה"כ	2,269.30	591.60	300.80	3,161.70	0.00	1,395.66	
2	8852	יטא 20 AC	14154689 - 12	26.30	10.10	28.30	64.70	0.00	25.38	0.09
			סה"כ	26.30	10.10	28.30	64.70	0.00	25.38	
3	8853	יטא 21 AC	14154689 - 13	1,182.00	367.80	328.60	1,878.40	0.00	805.23	11.46
			סה"כ	1,182.00	367.80	328.60	1,878.40	0.00	805.23	
4	8854	יטא 22 AC	14154689 - 14	25.30	9.70	27.40	62.40	0.00	24.46	0.09
			סה"כ	25.30	9.70	27.40	62.40	0.00	24.46	
5	8855	יטא 23 AC	14154688 - 13	0.00	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
6	8856	יטא ac1	14154688 - 1	2,221.10	653.40	314.40	3,188.90	0.00	1,401.46	4.75
			סה"כ	2,221.10	653.40	314.40	3,188.90	0.00	1,401.46	
7	8857	יטא ac10	14154688 - 10	0.00	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
8	8858	יטא ac11	14154689 - 1	1,507.40	499.70	232.60	2,239.70	0.00	979.25	2.05
			סה"כ	1,507.40	499.70	232.60	2,239.70	0.00	979.25	
9	8859	יטא ac12	14154689 - 2	1,212.80	396.80	201.40	1,811.00	0.00	790.38	2.33
			סה"כ	1,212.80	396.80	201.40	1,811.00	0.00	790.38	
10	8860	יטא ac13	14154689 - 3	3,771.40	1,412.50	3,809.20	8,993.10	0.00	3,545.48	6.34
			סה"כ	3,771.40	1,412.50	3,809.20	8,993.10	0.00	3,545.48	
11	8861	יטא ac14	14154689 - 4	0.00	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
12	8862	יטא ac15	14154689 - 5	0.00	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
13	8863	יטא ac16	14154689 - 6	1,341.80	517.00	1,476.20	3,335.00	0.00	1,305.75	2.53
			סה"כ	1,341.80	517.00	1,476.20	3,335.00	0.00	1,305.75	
14	8864	יטא ac17	14154689 - 7	0.00	0.00	0.00	0.00	0.00	0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	






מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	תשלום קבוע	סה"כ ש"ח	שיא ביקוש
15	8865	יטא ac18 פורק	14154689 - 8	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
16	8866	יטא ac2	14154688 - 2	4,418.00	1,411.50	716.00	6,545.50		2,860.30	7.34
			סה"כ	4,418.00	1,411.50	716.00	6,545.50	0.00	2,860.30	
17	8867	יטא ac27	14154689 - 9	7,267.00	2,326.20	1,182.00	10,775.20		4,707.92	10.62
			סה"כ	7,267.00	2,326.20	1,182.00	10,775.20	0.00	4,707.92	
18	8868	יטא ac3	14154688 - 3	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
19	8869	יטא ac4	14154688 - 4	206.60	68.40	48.70	323.70		139.56	0.30
			סה"כ	206.60	68.40	48.70	323.70	0.00	139.56	
20	8870	יטא ac5	14154688 - 5	7.50	2.80	9.10	19.40		7.53	0.02
			סה"כ	7.50	2.80	9.10	19.40	0.00	7.53	
21	8871	יטא ac6	14154688 - 6	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
22	8872	יטא ac7	14154688 - 7	62.70	25.20	79.70	167.60		64.85	0.89
			סה"כ	62.70	25.20	79.70	167.60	0.00	64.85	
23	8873	יטא ac8	14154688 - 8	11,080.90	3,588.00	1,802.10	16,471.00		7,194.67	15.35
			סה"כ	11,080.90	3,588.00	1,802.10	16,471.00	0.00	7,194.67	
24	8875	יטא ac9	14154688 - 9	4,616.30	1,469.00	738.00	6,823.30		2,983.16	8.63
			סה"כ	4,616.30	1,469.00	738.00	6,823.30	0.00	2,983.16	
25	8876	מגדל קירור 1+2	14154689 - 10	20,431.20	6,960.00	9,712.00	37,103.20		15,443.48	30.03
			סה"כ	20,431.20	6,960.00	9,712.00	37,103.20	0.00	15,443.48	
26	8877	מגדל קירור מס 3	14154688 - 12	9,906.40	3,458.00	9,884.60	23,249.00		9,175.72	18.27
			סה"כ	9,906.40	3,458.00	9,884.60	23,249.00	0.00	9,175.72	
27	8878	מגדל קירור מס 4	14154688 - 11	16,106.20	5,951.20	16,124.40	38,181.80		15,063.92	20.28
			סה"כ	16,106.20	5,951.20	16,124.40	38,181.80	0.00	15,063.92	
			סה"כ	87,660.20	29,718.90	47,015.50	164,394.60	0.00	67,914.18	
			חשבון חברת חשמל				0.00			
			הפרש בקוט"ש				164,394.60			
			הפרש באחוזים							





■ פסגה (Kwh 87,660.20)
■ גבע (Kwh 29,718.90)
■ שפל (Kwh 47,015.50)



■ פסגה (ש"ח 41,270.42)
■ גבע (ש"ח 11,608.20)
■ שפל (ש"ח 15,035.56)

