



**דוח שח + קוטש**

עבור: קניון הנגב מיזוג אויר צילרים על הגג

קבוצת עזריאלי בע"מ מיזוג אויר צילרים על הגג

תקופת דוח: (31/05/18 - 01/05/18)

תאריך הפקה: 03/06/18


מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	תשלום קבוע	סה"כ ש"ח	שיא ביקוש
1	8851	יטא 19 AC	11 - 14154689	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
2	8852	יטא 20 AC	12 - 14154689	183.90	67.60	192.70	444.20		175.47	9.79
			סה"כ	183.90	67.60	192.70	444.20	0.00	175.47	
3	8853	יטא 21 AC	13 - 14154689	105.00	27.10	71.00	203.10		83.00	8.92
			סה"כ	105.00	27.10	71.00	203.10	0.00	83.00	
4	8854	יטא 22 AC	14 - 14154689	214.90	15.60	12.70	243.20		111.15	3.72
			סה"כ	214.90	15.60	12.70	243.20	0.00	111.15	
5	8855	יטא 23 AC	13 - 14154688	64.20	24.00	68.00	156.20		61.65	0.23
			סה"כ	64.20	24.00	68.00	156.20	0.00	61.65	
6	8856	יטא ac1	1 - 14154688	1,178.50	127.30	41.90	1,347.70		616.85	32.15
			סה"כ	1,178.50	127.30	41.90	1,347.70	0.00	616.85	
7	8857	יטא ac10	10 - 14154688	1,166.70	251.90	0.00	1,418.60		646.43	38.98
			סה"כ	1,166.70	251.90	0.00	1,418.60	0.00	646.43	
8	8858	יטא ac11	1 - 14154689	815.70	342.50	908.70	2,066.90		812.55	4.25
			סה"כ	815.70	342.50	908.70	2,066.90	0.00	812.55	
9	8859	יטא ac12	2 - 14154689	2.00	0.00	0.00	2.00		0.94	6.22
			סה"כ	2.00	0.00	0.00	2.00	0.00	0.94	
10	8860	יטא ac13	3 - 14154689	82.40	30.10	83.20	195.70		77.53	3.85
			סה"כ	82.40	30.10	83.20	195.70	0.00	77.53	
11	8861	יטא ac14	4 - 14154689	7.60	0.00	0.00	7.60		3.57	5.02
			סה"כ	7.60	0.00	0.00	7.60	0.00	3.57	
12	8862	יטא ac15	5 - 14154689	1.00	70.40	0.00	71.40		28.01	15.26
			סה"כ	1.00	70.40	0.00	71.40	0.00	28.01	
13	8863	יטא ac16	6 - 14154689	1,282.40	62.80	0.00	1,345.20		626.78	28.82
			סה"כ	1,282.40	62.80	0.00	1,345.20	0.00	626.78	
14	8864	יטא ac17	7 - 14154689	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	






מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	תשלום קבוע	סה"כ ש"ח	שיא ביקוש
15	8865	יטא ac18 פורק	14154689 - 8	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
16	8866	יטא ac2	14154688 - 2	1,323.70	115.90	0.10	1,439.70		666.98	29.69
			סה"כ	1,323.70	115.90	0.10	1,439.70	0.00	666.98	
17	8867	יטא ac27	14154689 - 9	0.00	0.00	0.00	0.00		0.00	
			סה"כ	0.00	0.00	0.00	0.00	0.00	0.00	
18	8868	יטא ac3	14154688 - 3	7.70	2.80	8.10	18.60		7.35	0.03
			סה"כ	7.70	2.80	8.10	18.60	0.00	7.35	
19	8869	יטא ac4	14154688 - 4	33.20	0.00	0.00	33.20		15.59	14.04
			סה"כ	33.20	0.00	0.00	33.20	0.00	15.59	
20	8870	יטא ac5	14154688 - 5	1,148.20	117.20	17.10	1,282.50		590.60	19.66
			סה"כ	1,148.20	117.20	17.10	1,282.50	0.00	590.60	
21	8871	יטא ac6	14154688 - 6	45.70	2.10	1.50	49.30		22.77	25.08
			סה"כ	45.70	2.10	1.50	49.30	0.00	22.77	
22	8872	יטא ac7	14154688 - 7	6.50	1.60	3.30	11.40		4.75	9.94
			סה"כ	6.50	1.60	3.30	11.40	0.00	4.75	
23	8873	יטא ac8	14154688 - 8	1,186.50	105.20	0.00	1,291.70		598.33	34.52
			סה"כ	1,186.50	105.20	0.00	1,291.70	0.00	598.33	
24	8875	יטא ac9	14154688 - 9	1,641.00	171.90	228.10	2,041.00		912.04	39.15
			סה"כ	1,641.00	171.90	228.10	2,041.00	0.00	912.04	
25	8876	מגדל קירור 1+2	14154689 - 10	14,332.80	4,032.80	2,858.40	21,224.00		9,237.87	92.54
			סה"כ	14,332.80	4,032.80	2,858.40	21,224.00	0.00	9,237.87	
26	8877	מגדל קירור מס 3	14154688 - 12	0.40	0.00	0.00	0.40		0.19	1.53
			סה"כ	0.40	0.00	0.00	0.40	0.00	0.19	
27	8878	מגדל קירור מס 4	14154688 - 11	11,727.80	2,836.60	2,230.00	16,794.40		7,342.25	61.66
			סה"כ	11,727.80	2,836.60	2,230.00	16,794.40	0.00	7,342.25	
			סה"כ	36,557.80	8,405.40	6,724.80	51,688.00	0.00	22,642.64	
			חשבון חברת חשמל				0.00			
			הפרש בקוט"ש				51,688.00			
			הפרש באחוזים							





- פסגה (36,557.80 Kwh)
- גבע (8,405.40 Kwh)
- שפל (6,724.80 Kwh)



- פסגה (17,167.54 ₪)
- גבע (3,288.19 ₪)
- שפל (2,186.90 ₪)

