



**דוח קוט"ש**

עבור: מליסרון

דוח מסכם עבור: פארק עופר בניין 4


תקופת דוח: (01/03/19 - 31/03/19)

תאריך הפקה: 07/04/19

מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	17.80	4,143.83	914.39	357.26	2,872.17	00021940 - 5	אגילנט LDA ק.7	11729	1
		4,143.83	914.39	357.26	2,872.17	סה"כ צריכה			
	75.89	41,362.68	16,326.66	6,783.19	18,252.83	00006068 - 4	אנברה	11795	2
	22.87	7,241.50	2,160.80	1,013.18	4,067.52	00006068 - 5			
	25.36	7,278.56	1,580.94	906.64	4,790.98	00006068 - 6			
		6,996.70	2,088.04	979.97	3,928.69	00006366 - 2			
		6,204.71	1,303.98	804.26	4,096.46	00006366 - 3			
		103,084.55	36,209.74	16,414.13	50,460.68	00006366 - 4			
		5,847.10	1,186.56	834.64	3,825.90	00006366 - 6			
	0.85	454.44	182.64	76.76	195.05	00021940 - 6			
	7.14	1,094.72	279.51	94.95	720.26	00021940 - 7			
	0.88	388.75	148.46	62.99	177.30	00021940 - 8			
	1.85	669.32	271.01	112.31	286.00	00022129 - 4			
	1.80	718.65	262.92	111.42	344.32	00022129 - 5			
	1.58	516.84	190.30	78.50	248.04	00022129 - 6			
	0.84	327.29	123.60	53.14	150.55	00022129 - 7			
	2.39	311.64	110.95	47.70	152.99	00022129 - 8			
	1.44	454.83	158.20	65.93	230.70	00022585 - 1			
	1.16	359.62	120.11	50.001	189.51	00022585 - 2			
	0.64	230.45	96.59	39.68	94.18	00022585 - 3			
	2.86	1,365.82	605.60	236.95	523.27	00024801 - 6			
		184,908.17	63,406.60	28,766.36	92,735.22	סה"כ צריכה			
	6.79	1,656.87	550.67	197.12	909.09	00024801 - 2	ווריג'י מכונה	11731	3
		1,656.87	550.67	197.12	909.09	סה"כ צריכה			
	0.82	574.07	246.60	100.63	226.84	00006068 - 1	מ"א גג	11794	4
	17.22	12,653.28	5,400.43	2,214.21	5,038.64	00006068 - 8			
		44,374.76	15,628.84	7,877.84	20,868.08	00006366 - 1			
		2,598.79	188.98	429.66	1,980.16	00006366 - 7			
	19.32	14,214.61	6,069.09	2,492.10	5,653.42	00021940 - 1			
	17.55	-0.001	0.00	0.00	-0.001	00021940 - 2			
		0.00	0.00	0.00	0.00	00021940 - 3			
	0.002	0.00	0.00	0.00	0.00	00021940 - 4			



מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	21.85	16,002.59	6,828.35	2,801.56	6,372.68	00022129 - 1			
	73.62	28,974.99	10,285.91	4,952.18	13,736.90	00024801 - 1			
		119,393.10	44,648.19	20,868.18	53,876.72	סה"כ צריכה			
	32.66	18,620.69	6,274.69	3,158.68	9,187.32	00006068 - 2	פארק אזורים	11792	5
	75.86	26,816.78	9,747.29	4,329.10	12,740.40	00006068 - 3			
	19.32	-14,214.61	-6,069.09	-2,492.10	-5,653.42	00021940 - 1			
	17.55	0.001	0.00	0.00	0.001	00021940 - 2			
		0.00	0.00	0.00	0.00	00021940 - 3			
	0.002	0.00	0.00	0.00	0.00	00021940 - 4			
	11.70	1,491.94	591.46	224.27	676.21	00022585 - 4			
	1.38	206.28	71.84	31.47	102.97	00022585 - 5			
	1.82	15.67	4.87	2.69	8.11	00022585 - 6			
	16.15	1,071.87	501.91	262.98	306.98	00022585 - 7			
	1.02	209.35	75.60	34.27	99.48	00024538 - 1			
	0.02	13.31	5.76	2.36	5.19	00024690 - 1			
	1.40	392.55	143.91	57.67	190.97	00024801 - 3			
	0.82	186.39	79.99	33.05	73.36	00024801 - 4			
	2.06	898.89	343.62	140.84	414.44	00024801 - 5			
	1.22	557.27	228.42	105.54	223.30	00024801 - 7			
	0.49	307.44	131.93	54.24	121.27	00024801 - 8			
	1.90	162.00	66.60	28.20	67.20	18170708 - 1			
		0.00	0.00	0.00	0.00	18170708 - 2			
		0.00	0.00	0.00	0.00	18170708 - 3			
		36,735.83	12,198.81	5,973.25	18,563.77	סה"כ צריכה			
	34.11	10,257.51	3,441.50	1,416.20	5,399.81	00006068 - 7	קיסייט	11793	6
		7,453.27	1,483.16	829.56	5,140.54	00006366 - 5			
	1.78	840.47	344.80	141.37	354.30	00022129 - 2			
	12.40	7,226.37	3,065.09	1,267.77	2,893.51	00022129 - 3			
		25,777.61	8,334.55	3,654.90	13,788.17	סה"כ צריכה			
		372,615.40	130,053.21	59,817.06	182,745.13	סה"כ צריכה			
		364,475.13	133,579.00	58,867.50	172,028.63	חשבון חברת חשמל			
		8,140.27	-3,525.79	949.56	10,716.50	הפרש בקוט"ש			
		2.23%	-2.64%	1.61%	6.23%	הפרש באחוזים			



- פסגה (Kwh 182,745.13)
- גבע (Kwh 59,817.06)
- שפל (Kwh 130,053.21)

