



**דוח קוט"ש**

עבור: מליסרון

דוח מסכם עבור: פארק עופר בניין 4

תקופת דוח: (01/03/19 - 31/03/19)

תאריך הפקה: 07/04/19


מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	17.80	4,143.83	914.39	357.26	2,872.17	00021940 - 5	אגילנט LDA ק.7	11729	1
		4,143.83	914.39	357.26	2,872.17	סה"כ צריכה			
	75.89	41,362.68	16,326.66	6,783.19	18,252.83	00006068 - 4	אנברה	11795	2
	22.87	7,241.50	2,160.80	1,013.18	4,067.52	00006068 - 5			
	25.36	7,278.56	1,580.94	906.64	4,790.98	00006068 - 6			
		6,996.70	2,088.04	979.97	3,928.69	00006366 - 2			
		6,204.71	1,303.98	804.26	4,096.46	00006366 - 3			
		103,084.55	36,209.74	16,414.13	50,460.68	00006366 - 4			
		5,847.10	1,186.56	834.64	3,825.90	00006366 - 6			
	0.85	454.44	182.64	76.76	195.05	00021940 - 6			
	7.14	1,094.72	279.51	94.95	720.26	00021940 - 7			
	0.88	388.75	148.46	62.99	177.30	00021940 - 8			
	1.85	669.32	271.01	112.31	286.00	00022129 - 4			
	1.80	718.65	262.92	111.42	344.32	00022129 - 5			
	1.58	516.84	190.30	78.50	248.04	00022129 - 6			
	0.84	327.29	123.60	53.14	150.55	00022129 - 7			
	2.39	311.64	110.95	47.70	152.99	00022129 - 8			
	1.44	454.83	158.20	65.93	230.70	00022585 - 1			
	1.16	359.62	120.11	50.001	189.51	00022585 - 2			
	0.64	230.45	96.59	39.68	94.18	00022585 - 3			
	2.86	1,365.82	605.60	236.95	523.27	00024801 - 6			
		184,908.17	63,406.60	28,766.36	92,735.22	סה"כ צריכה			
	6.79	1,656.87	550.67	197.12	909.09	00024801 - 2	ווריג'י מכונה	11731	3
		1,656.87	550.67	197.12	909.09	סה"כ צריכה			
	0.82	574.07	246.60	100.63	226.84	00006068 - 1	מ"א גג	11794	4
	17.22	12,653.28	5,400.43	2,214.21	5,038.64	00006068 - 8			
		32,324.76	15,628.84	6,827.84	9,868.08	00006366 - 1			
		2,598.79	188.98	429.66	1,980.16	00006366 - 7			
	19.32	14,214.61	6,069.09	2,492.10	5,653.42	00021940 - 1			
	17.55	-0.001	0.00	0.00	-0.001	00021940 - 2			
		0.00	0.00	0.00	0.00	00021940 - 3			
	0.002	0.00	0.00	0.00	0.00	00021940 - 4			





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
			00022129 - 1	6,372.68	2,801.56	6,828.35	16,002.59	21.85	
			00024801 - 1	13,736.90	4,952.18	10,285.91	28,974.99	73.62	
			סה"כ צריכה	42,876.72	19,818.18	44,648.19	107,343.10		
5	11792	פארק אזורים	00006068 - 2	9,187.32	3,158.68	6,274.69	18,620.69	32.66	
			00006068 - 3	12,740.40	4,329.10	9,747.29	26,816.78	75.86	
			00021940 - 1	-5,653.42	-2,492.10	-6,069.09	-14,214.61	19.32	
			00021940 - 2	0.001	0.00	0.00	0.001	17.55	
			00021940 - 3	0.00	0.00	0.00	0.00		
			00021940 - 4	0.00	0.00	0.00	0.00	0.002	
			00022585 - 4	676.21	224.27	591.46	1,491.94	11.70	
			00022585 - 5	102.97	31.47	71.84	206.28	1.38	
			00022585 - 6	8.11	2.69	4.87	15.67	1.82	
			00022585 - 7	306.98	262.98	501.91	1,071.87	16.15	
			00024538 - 1	99.48	34.27	75.60	209.35	1.02	
			00024690 - 1	5.19	2.36	5.76	13.31	0.02	
			00024801 - 3	190.97	57.67	143.91	392.55	1.40	
			00024801 - 4	73.36	33.05	79.99	186.39	0.82	
			00024801 - 5	414.44	140.84	343.62	898.89	2.06	
			00024801 - 7	223.30	105.54	228.42	557.27	1.22	
			00024801 - 8	121.27	54.24	131.93	307.44	0.49	
			18170708 - 1	67.20	28.20	66.60	162.00	1.90	
			18170708 - 2	0.00	0.00	0.00	0.00		
			18170708 - 3	0.00	0.00	0.00	0.00		
			סה"כ צריכה	18,563.77	5,973.25	12,198.81	36,735.83		
6	11793	קיסייט	00006068 - 7	5,399.81	1,416.20	3,441.50	10,257.51	34.11	
			00006366 - 5	5,140.54	829.56	1,483.16	7,453.27		
			00022129 - 2	354.30	141.37	344.80	840.47	1.78	
			00022129 - 3	2,893.51	1,267.77	3,065.09	7,226.37	12.40	
			סה"כ צריכה	13,788.17	3,654.90	8,334.55	25,777.61		
			סה"כ צריכה	171,745.13	58,767.06	130,053.21	360,565.40		
			חשבון חברת חשמל	172,028.63	58,867.50	133,579.00	364,475.13		
			הפרש בקוט"ש	-283.50	-100.44	-3,525.79	-3,909.73		
			הפרש באחוזים	-0.16%	-0.17%	-2.64%	-1.07%		





- פסגה (Kwh 171,745.13)
- גבע (Kwh 58,767.06)
- שפל (Kwh 130,053.21)

