



דוח קוט"ש

עבור: מליסרון

דוח מסכם עבור: פארק עופר בניין 4


תקופת דוח: (01/06/19 - 30/06/19)

תאריך הפקה: 02/07/19

מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	16.48	4,506.02	1,053.28	415.58	3,037.16	00021940 - 5	אגילנט LDA ק.7	11729	1
		4,506.02	1,053.28	415.58	3,037.16	סה"כ צריכה			
	6.19	2,419.83	833.44	319.92	1,266.47	00024801 - 2	אילומיניט	11731	2
		2,419.83	833.44	319.92	1,266.47	סה"כ צריכה			
	65.52	34,418.14	13,920.72	5,296.60	15,200.82	00006068 - 4	אנברה	11795	3
	16.94	6,929.59	2,657.49	997.99	3,274.12	00006068 - 5			
	25.66	6,928.07	1,547.20	771.05	4,609.82	00006068 - 6			
	23.14	7,863.76	2,496.75	983.82	4,383.18	00006366 - 2			
	24.79	5,923.70	1,174.88	560.66	4,188.16	00006366 - 3			
	156.77	91,559.62	36,994.93	14,148.72	40,415.96	00006366 - 4			
	25.10	6,460.67	1,405.40	686.88	4,368.40	00006366 - 6			
	0.91	465.27	193.44	74.08	197.75	00021940 - 6			
	3.41	734.26	211.24	94.68	428.34	00021940 - 7			
	0.84	426.67	174.67	69.79	182.21	00021940 - 8			
	1.82	625.75	266.16	100.53	259.06	00022129 - 4			
	1.69	674.61	260.92	98.74	314.95	00022129 - 5			
	1.59	496.81	183.50	70.60	242.70	00022129 - 6			
	0.90	358.59	140.69	54.75	163.15	00022129 - 7			
	1.14	286.61	111.30	43.71	131.60	00022129 - 8			
	1.45	448.00	157.92	61.45	228.63	00022585 - 1			
	1.21	332.58	119.67	45.75	167.16	00022585 - 2			
	0.56	178.08	75.46	28.31	74.31	00022585 - 3			
	2.16	1,304.74	602.33	216.74	485.67	00024801 - 6			
		166,415.53	62,694.70	24,404.83	79,316.00	סה"כ צריכה			
	102.79	39,438.06	13,533.18	5,420.54	20,484.34	00006068 - 1	מ"א גג	11794	4
	16.98	11,890.29	5,239.70	1,968.06	4,682.53	00006068 - 8			
	122.57	49,363.76	17,326.76	7,504.94	24,532.06	00006366 - 1			
	65.78	16,142.86	877.91	1,501.22	13,763.72	00006366 - 7			
	0.002	0.00	0.00	0.00	0.00	00021940 - 1			
	17.16	12,030.10	5,304.04	1,992.05	4,734.01	00021940 - 2			
	18.76	13,231.11	5,842.99	2,193.45	5,194.67	00021940 - 3			
		0.00	0.00	0.00	0.00	00021940 - 4			



מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
			00022129 - 1	5,705.89	2,395.57	6,377.54	14,479.00	20.74	
			00024801 - 1	18,405.74	5,239.52	12,366.72	36,011.98	94.43	
			סה"כ צריכה	97,502.96	28,215.36	66,868.84	192,587.16		
5	11792	פארק אזורים	00006068 - 2	12,912.91	4,725.22	11,324.30	28,962.43	47.45	
			00006068 - 3	11,832.64	3,844.30	9,528.86	25,205.80	70.49	
			00021940 - 1	0.00	0.00	0.00	0.00	0.002	
			00021940 - 2	-4,734.01	-1,992.05	-5,304.04	-12,030.10	17.16	
			00021940 - 3	-5,194.67	-2,193.45	-5,842.99	-13,231.11	18.76	
			00021940 - 4	0.00	0.00	0.00	0.00		
			00022585 - 4	733.28	263.85	661.41	1,658.53	2.97	
			00022585 - 5	125.86	35.84	93.19	254.89	1.35	
			00022585 - 6	262.74	36.67	92.44	391.85	4.20	
			00022585 - 7	649.57	240.49	642.55	1,532.61	4.67	
			00024538 - 1	-191.02	-62.03	-151.34	-404.39	0.69	
			00024690 - 1	5.01	2.23	5.97	13.22	0.02	
			00024801 - 3	230.48	87.94	223.30	541.73	1.39	
			00024801 - 4	40.97	17.60	46.81	105.37	0.20	
			00024801 - 5	412.99	140.07	370.11	923.17	2.06	
			00024801 - 7	211.02	100.13	228.23	539.38	1.18	
			00024801 - 8	94.19	42.36	114.76	251.32	1.67	
			18170708 - 1	301.20	120.60	320.60	742.40	1.25	
			18170708 - 2	0.00	0.00	0.00	0.00		
			18170708 - 3	0.00	0.00	0.00	0.00		
			סה"כ צריכה	17,693.17	5,409.77	12,354.17	35,457.10		
6	11793	קיסייט	00006068 - 7	4,353.94	774.20	1,988.54	7,116.68	22.43	
			00006366 - 5	5,711.02	870.40	1,739.88	8,321.30	26.42	
			00022129 - 2	298.42	119.52	317.09	735.03	1.26	
			00022129 - 3	2,859.12	1,233.09	3,228.83	7,321.04	13.13	
			סה"כ צריכה	13,222.50	2,997.21	7,274.34	23,494.05		
			סה"כ צריכה	212,038.25	61,762.67	151,078.76	424,879.69		
			חשבון חברת חשמל	208,017.88	62,284.25	153,641.00	423,943.13		
			הפרש בקוט"ש	4,020.37	-521.58	-2,562.24	936.56		
			הפרש באחוזים	1.93%	-0.84%	-1.67%	0.22%		



- פסגה (Kwh 212,038.25)
- גבע (Kwh 61,762.67)
- שפל (Kwh 151,078.76)

