



דוח קוט"ש

עבור: מליסרון

דוח מסכם עבור: פארק עופר בניין 4

תקופת דוח: (31/12/19 - 01/12/19)

תאריך הפקה: 07/01/20


מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	19.47	4,766.74	3,347.76	259.72	1,159.26	00021940 - 5	אגילנט LDA ק.7	11729	1
		4,766.74	3,347.76	259.72	1,159.26	סה"כ צריכה			
	5.63	3,704.78	1,474.33	481.08	1,749.36	00024801 - 2	אילומיניט	11731	2
		3,704.78	1,474.33	481.08	1,749.36	סה"כ צריכה			
	0.02	0.01	0.00	0.00	0.01	00006068 - 4	אנברה	11795	3
		0.00	0.00	0.00	0.00	00006068 - 5			
		0.00	0.00	0.00	0.00	00006068 - 6			
	0.02	-0.07	-0.06	-0.004	-0.01	00006366 - 2			
	0.03	0.04	0.03	0.02	-0.01	00006366 - 3			
	0.10	-0.02	-0.04	0.00	0.01	00006366 - 4			
	0.02	-0.004	-0.03	-0.004	0.03	00006366 - 6			
	0.11	29.19	18.80	4.08	6.30	00021940 - 6			
	4.80	416.80	308.26	51.93	56.61	00021940 - 7			
	0.48	224.64	157.99	23.23	43.42	00021940 - 8			
	1.25	323.67	232.08	30.94	60.65	00022129 - 4			
	1.23	249.27	178.51	24.14	46.61	00022129 - 5			
	0.74	186.54	133.65	18.16	34.73	00022129 - 6			
	0.12	63.55	45.51	6.07	11.97	00022129 - 7			
	0.40	187.59	132.00	19.32	36.27	00022129 - 8			
	0.55	282.34	201.66	27.32	53.36	00022585 - 1			
	0.68	200.95	143.37	19.47	38.11	00022585 - 2			
	0.31	163.59	116.80	15.77	31.02	00022585 - 3			
	1.95	1,374.54	501.80	166.35	706.39	00024801 - 6			
		3,702.62	2,170.34	406.81	1,125.47	סה"כ צריכה			
	56.26	605.72	437.46	54.46	113.81	00006068 - 1	מ"א גג	11794	4
	18.40	13,481.00	9,581.74	1,239.51	2,659.75	00006068 - 8			
	39.50	625.22	453.44	55.62	116.16	00006366 - 1			
	22.13	525.29	375.66	48.37	101.26	00006366 - 7			
	0.004	0.02	0.01	0.003	0.003	00021940 - 1			
	18.40	26.54	26.54	0.0010	0.00	00021940 - 2			
	16.49	11.10	11.10	0.00	-0.001	00021940 - 3			
	0.002	0.00	-0.0010	0.00	0.0010	00021940 - 4			





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
			00022129 - 1	9.34	4.55	48.47	62.36	22.18	
			00024801 - 1	2,609.41	2,639.12	16,211.00	21,459.53	64.84	
			סה"כ צריכה	5,609.73	4,041.63	27,145.43	36,796.78		
5	11792	פארק אזורים	00006068 - 2	1,314.46	664.26	4,517.52	6,496.24	18.55	
			00006068 - 3	2,968.10	1,322.09	10,447.25	14,737.44	51.91	
			00021940 - 1	-0.003	-0.003	-0.01	-0.02	0.004	
			00021940 - 2	0.00	-0.0010	-26.54	-26.54	18.40	
			00021940 - 3	0.001	0.00	-11.10	-11.10	16.49	
			00021940 - 4	-0.0010	0.00	0.0010	0.00	0.002	
			00022585 - 4	240.64	112.78	827.74	1,181.15	4.46	
			00022585 - 5	52.13	24.41	188.41	264.95	1.38	
			00022585 - 6	273.10	63.01	916.92	1,253.02	20.70	
			00022585 - 7	551.35	193.56	1,604.15	2,349.06	6.83	
			00024538 - 1	29.23	13.80	103.98	147.02	0.44	
			00024690 - 1	2.86	1.37	10.36	14.59	0.02	
			00024801 - 3	137.99	65.38	167.08	370.45	1.27	
			00024801 - 4	109.16	33.01	82.97	225.14	0.28	
			00024801 - 5	479.76	131.60	852.01	1,463.38	1.30	
			00024801 - 7	288.38	71.79	206.16	566.32	1.06	
			00024801 - 8	156.64	60.21	131.21	348.06	0.41	
			18170708 - 1	159.80	70.00	572.60	802.40	3.00	
			18170708 - 2	0.00	0.00	0.00	0.00		
			18170708 - 3	0.00	0.00	0.00	0.00		
			סה"כ צריכה	6,763.60	2,827.26	20,590.69	30,181.55		
6	11793	קיסייט	00006068 - 7	2,135.65	545.70	6,319.82	9,001.17	36.69	
			00006366 - 5	2,453.58	823.42	6,041.86	9,318.85	48.57	
			00022129 - 2	158.58	69.33	567.52	795.43	3.01	
			00022129 - 3	1,182.94	551.78	4,228.18	5,962.90	9.62	
			סה"כ צריכה	5,930.75	1,990.22	17,157.38	25,078.35		
			סה"כ צריכה	22,338.16	10,006.74	71,885.93	104,230.83		
			חשבון חברת חשמל	21,165.13	8,918.00	71,037.88	101,121.01		
			הפרש בקוט"ש	1,173.03	1,088.74	848.05	3,109.82		
			הפרש באחוזים	5.54%	12.21%	1.19%	3.08%		





- פיסגה (Kwh 22,338.16)
- גבע (Kwh 10,006.74)
- שפל (Kwh 71,885.93)

