



דוח קוט"ש

עבור: הון ניהול

דוח מסכם עבור: פארק הייטק רעננה בנין E

תקופת דוח: (01/02/20 - 29/02/20)

תאריך הפקה: 09/03/20

מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
		15,478.85	11,079.00	1,479.88	2,919.97	80003223 - 6	ARM UPS - חדר חשמל ראשי בחניון	28618	1
		15,478.85	11,079.00	1,479.88	2,919.97	סה"כ צריכה			
		0.70	0.52	0.08	0.09	80002031 - 3	ARM קומה 2	27969	2
		4,471.26	3,130.03	336.97	1,004.26	80003223 - 2			
		4,471.95	3,130.56	337.04	1,004.35	סה"כ צריכה			
		-0.74	-0.52	-0.08	-0.13	80002031 - 4	ARM קומה 3	27966	3
	23.20	2,815.20	1,995.20	220.00	600.00	80003257 - 7			
	21.70	6,560.40	4,521.60	597.80	1,441.00	81017159 - 4			
		9,374.86	6,516.27	817.72	2,040.87	סה"כ צריכה			
		0.71	0.52	0.07	0.11	80002031 - 5	ARM קומה 4	27970	4
	30.40	5,355.20	3,427.20	483.20	1,444.80	80003224 - 7			
		5,355.91	3,427.72	483.27	1,444.91	סה"כ צריכה			
	18.40	4,798.40	2,927.20	502.40	1,368.80	80001690 - 3	ARM קומה 7	27968	5
		0.72	0.51	0.07	0.14	80002031 - 8			
	15.40	5,269.30	3,611.70	496.50	1,161.10	81017159 - 8			
		10,068.42	6,539.41	998.97	2,530.04	סה"כ צריכה			
	3.47	1,294.05	861.40	118.00	314.65	15091250 - 1	NICE	13026	6
	0.50	184.85	123.00	16.85	45.00	15091250 - 2			
	0.21	21.40	13.00	0.20	8.20	16092121 - 1			
	46.40	4,422.00	3,305.20	284.40	832.40	80001690 - 6			
		7,495.16	6,145.25	962.53	387.38	80001767 - 2			
		18.68	14.57	1.46	2.65	80001767 - 4			
		0.00	0.00	0.00	0.00	80001767 - 5			
	9.60	3,220.00	2,303.20	295.20	621.60	80003224 - 4			
	2.90	268.40	190.25	39.80	38.35	80003257 - 5			
		16,924.54	12,955.86	1,718.44	2,250.23	סה"כ צריכה			
	1.18	282.70	181.50	1.90	99.30	15091162 - 1	ORCA קומה 5	13028	7
	0.57	40.50	27.00	0.00	13.50	15091162 - 3			
	10.58	173.40	151.10	0.10	22.20	15091162 - 4			
	65.85	248.60	178.50	19.70	50.40	16048009 - 1			
	1.05	241.40	151.60	2.00	87.80	16048009 - 2			
		986.60	689.70	23.70	273.20	סה"כ צריכה			





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטי"ש	שיא ביקוש	מקדם הספק
8	13017	ORCA קומה 6	16092121 - 3	460.00	234.08	1,780.00	2,474.08	4.61	
			16092121 - 4	1,585.60	805.44	6,113.92	8,504.96	15.98	
			80001690 - 2	826.40	231.20	2,972.00	4,029.60	16.80	
			80002031 - 7	443.24	191.64	1,637.27	2,272.14		
			81017159 - 7	579.30	147.50	1,482.10	2,208.90	6.10	
			סה"כ צריכה	3,894.54	1,609.86	13,985.29	19,489.68		
9	34774	נייס מעבדה ראשית שנאי 3	0333 - 1	53,914.32	26,272.50	198,550.85	278,737.67		
			סה"כ צריכה	53,914.32	26,272.50	198,550.85	278,737.67		
10	13021	סיברביט	80002031 - 2	63.36	30.06	231.17	324.59		
			80003217 - 7	0.00	0.00	0.00	0.00		
			80003271 - 4	51.80	21.10	183.60	256.50		
			סה"כ צריכה	115.16	51.16	414.77	581.09		
11	25873	סיברביט סולושנס	16092121 - 2	481.40	244.40	1,852.80	2,578.60	3.76	
			80001690 - 4	0.00	0.00	0.00	0.00		
			80001976 - 1	1.22	0.14	1.33	2.69		
			80001976 - 2	0.51	0.26	1.98	2.76		
			80001976 - 5	-246.20	-121.94	-905.88	-1,274.01		
			80001976 - 6	162.86	82.84	627.28	872.97		
			סה"כ צריכה	399.79	205.70	1,577.52	2,183.01		
12	13016	ציבורי	15091162 - 1	-99.30	-1.90	-181.50	-282.70	1.18	
			15091162 - 3	-13.50	0.00	-27.00	-40.50	0.57	
			15091162 - 4	-22.20	-0.10	-151.10	-173.40	10.58	
			15091249 - 1	1.10	0.00	0.45	1.55	0.74	
			15091249 - 2	1.00	0.00	0.40	1.40	0.67	
			15091249 - 3	10.55	4.80	36.70	52.05	0.81	
			15091249 - 7	0.00	0.00	0.00	0.00		
			15091249 - 8	0.00	0.00	0.00	0.00		
			15091249 - 9	0.00	0.00	0.00	0.00		
			- 10 15091249	0.00	0.00	0.00	0.00		
			- 11 15091249	0.00	0.00	0.00	0.00		
			- 12 15091249	0.00	0.00	0.00	0.00		
			15091250 - 3	0.00	0.00	0.00	0.00		
			15091250 - 4	0.00	0.00	0.00	0.00		
			15091250 - 5	0.00	0.00	0.00	0.00		
			15091250 - 7	0.00	0.00	0.00	0.00		






מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטי"ש	שיא ביקוש	מקדם הספק
			15091250 - 8	0.00	0.00	0.00	0.00		
			15091250 - 9	0.00	0.00	0.00	0.00		
			- 10 15091250	0.00	0.00	0.00	0.00		
			- 11 15091250	0.00	0.00	0.00	0.00		
			- 12 15091250	0.00	0.00	0.00	0.00		
			16048009 - 1	-50.40	-19.70	-178.50	-248.60	65.85	
			16048009 - 2	-87.80	-2.00	-151.60	-241.40	1.05	
			16092120 - 2	0.00	0.00	0.00	0.00		
			16092120 - 3	89.00	43.20	326.60	458.80	1.16	
			16092120 - 4	0.00	0.00	0.00	0.00		
			80001690 - 1	68.80	34.40	265.60	368.80	0.80	
			80001690 - 5	460.80	976.80	6,297.60	7,735.20	95.20	
			80001767 - 1	460.43	978.74	6,285.36	7,724.53		
			80001767 - 2	-387.38	-962.53	-6,145.25	-7,495.16		
			80001767 - 3	407.34	111.08	1,011.88	1,530.30		
			80001767 - 4	-2.65	-1.46	-14.57	-18.68		
			80001767 - 5	0.00	0.00	0.00	0.00		
			80001976 - 7	123.79	61.26	475.43	660.48		
			80001976 - 8	1.90	0.95	7.25	10.10		
			80002031 - 1	155.53	89.58	664.37	909.48		
			80003217 - 1	1.36	0.69	5.25	7.30		
			80003217 - 2	1.33	0.68	5.16	7.18		
			80003223 - 4	3,059.01	1,311.30	11,539.30	15,909.61		
			80003224 - 3	0.00	0.00	0.00	0.00		
			80003224 - 6	93.60	47.20	463.20	604.00	183.20	
			80003257 - 2	1.20	118.20	18.40	137.80	3.80	
			80003257 - 3	1.30	0.60	5.00	6.90	7.30	
			80003257 - 4	2,572.80	1,052.80	6,992.80	10,618.40	56.80	
			80003257 - 6	50.80	25.80	195.60	272.20	0.40	
			80003257 - 8	1,102.40	789.60	3,516.00	5,408.00	114.40	
			80003271 - 2	468.60	178.40	1,491.40	2,138.40		
			80003271 - 3	-80.10	-37.85	-292.70	-410.65		
			80003271 - 5	147.10	60.70	437.10	644.90		
			80003271 - 6	717.90	311.90	2,680.80	3,710.60		
			80003271 - 7	342.40	153.70	1,486.60	1,982.70		
			80003271 - 8	0.00	0.00	0.00	0.00		





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
			81017159 - 1	525.50	337.20	1,985.00	2,847.70	11.40	
			81017159 - 2	1,423.10	702.70	5,592.00	7,717.80	16.90	
			סה"כ צריכה	11,545.30	6,366.74	44,643.04	62,555.08		
13	25872	קומה 8 סייברביט	16092120 - 1	183.60	90.10	696.10	969.80	2.20	
			80001976 - 3	265.46	134.74	1,021.08	1,421.28		
			80001976 - 4	265.88	135.07	1,022.61	1,423.56		
			80003217 - 6	4,613.88	2,334.31	17,737.77	24,685.95		
			80003224 - 5	979.20	419.20	3,713.60	5,112.00	76.00	
			80003271 - 1	1,078.50	297.20	2,474.50	3,850.20		
			סה"כ צריכה	7,386.51	3,410.63	26,665.66	37,462.79		
14	13027	תדהר	15091162 - 1	-99.30	-1.90	-181.50	-282.70	1.18	
			15091162 - 3	-13.50	0.00	-27.00	-40.50	0.57	
			15091162 - 4	-22.20	-0.10	-151.10	-173.40	10.58	
			16048009 - 1	-50.40	-19.70	-178.50	-248.60	65.85	
			16048009 - 2	-87.80	-2.00	-151.60	-241.40	1.05	
			16092121 - 3	115.00	58.52	445.00	618.52	4.61	
			16092121 - 4	396.40	201.36	1,528.48	2,126.24	15.98	
			80002031 - 6	100.82	46.00	399.05	545.87		
			80003224 - 8	204.00	29.60	721.60	955.20	17.60	
			81017159 - 6	278.80	47.60	682.90	1,009.30	6.40	
			סה"כ צריכה	821.82	359.38	3,087.34	4,268.53		
			סה"כ צריכה	90,541.00	44,135.00	333,263.00	467,938.99		
			חשבון חברת חשמל	90,541.00	44,135.00	333,263.00	467,939.00		
			הפרש בקוט"ש	0.0005	-0.005	-0.004	-0.008		
			הפרש באחוזים	0.00%	-0.00%	-0.00%	-0.00%		



■ פסגה (90,541.00 Kwh) 19%
■ גבע (44,135.00 Kwh) 9%
■ שפל (333,263.00 Kwh) 71%





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטי"ש	שיא ביקוש	מקדם הספק
1	12425	מפסק ראשי שדה חיוני	80003223 - 1	21,262.37	9,347.52	73,408.51	104,018.40		
			סה"כ צריכה	21,262.37	9,347.52	73,408.51	104,018.40		
2	12421	צילר 4 על הגג- ציבורי מדידה של נייס משלמים לחח"י	80003224 - 2	9,904.80	4,951.20	36,856.00	51,712.00	196.00	
			סה"כ צריכה	9,904.80	4,951.20	36,856.00	51,712.00		
3	12427	ראשי שנאי AT1	80003257 - 1	7,891.20	4,275.20	28,620.80	40,787.20	217.60	
			סה"כ צריכה	7,891.20	4,275.20	28,620.80	40,787.20		
4	12428	ראשי שנאי AT2	80003224 - 1	26,016.00	11,129.60	88,460.80	125,606.40	320.00	
			סה"כ צריכה	26,016.00	11,129.60	88,460.80	125,606.40		

