



**דוח קוט"ש**

עבור: אזורים

דוח מסכם עבור: בניין דקל

תקופת דוח: (01/11/21 - 30/11/21)

תאריך הפקה: 04/12/21


מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	70.85	1,794.14	379.19	144.14	1,270.81	00006068 - 1	מ"א גג	11794	1
	22.62	13,555.55	5,737.89	2,272.81	5,544.85	00006068 - 8			
	79.97	1,841.93	385.97	149.93	1,306.03	00006366 - 1			
	128.23	31,724.34	10,825.36	4,871.80	16,027.19	00006366 - 7			
	0.02	0.06	0.02	0.003	0.03	00021940 - 1			
	20.95	1,307.70	368.58	122.95	816.17	00021940 - 2			
	0.55	0.28	0.00	0.001	0.27	00021940 - 3			
	21.80	1,783.75	542.59	167.73	1,073.43	00021940 - 4			
	23.10	13,908.94	5,901.28	2,336.71	5,670.95	00022129 - 1			
	63.06	1,457.48	159.64	62.34	1,235.51	00022139 - 1			
		67,374.17	24,300.51	10,128.41	32,945.25	סה"כ צריכה			
	54.14	10,263.95	3,808.27	1,390.67	5,065.01	00006068 - 2	פארק אזורים	11792	2
	63.58	15,205.00	4,428.65	2,012.20	8,764.15	00006068 - 3			
	0.02	-0.06	-0.02	-0.003	-0.03	00021940 - 1			
	20.95	-1,307.70	-368.58	-122.95	-816.17	00021940 - 2			
	0.55	-0.28	0.00	-0.001	-0.27	00021940 - 3			
	21.80	-1,783.75	-542.59	-167.73	-1,073.43	00021940 - 4			
	1.17	316.38	117.68	47.26	151.44	00022139 - 3			
	0.26	62.76	25.07	9.84	27.85	00022139 - 4			
	1.43	380.98	104.51	61.69	214.78	00022139 - 5			
	1.29	687.93	332.58	117.90	237.45	00022139 - 7			
	6.93	1,601.44	461.91	209.24	930.29	00022139 - 8			
	2.68	1,021.25	461.01	168.85	391.38	00022585 - 5			
	1.25	191.17	78.13	30.59	82.45	00022585 - 6			
	4.38	1,418.27	595.81	231.26	591.20	00022585 - 7			
	0.02	12.63	5.34	2.06	5.23	00024690 - 1			
	0.99	169.50	69.80	26.90	72.80	17313494 - 1			
		0.00	0.00	0.00	0.00	18170708 - 2			
		0.00	0.00	0.00	0.00	18170708 - 3			
		28,239.45	9,577.56	4,017.79	14,644.10	סה"כ צריכה			
	42.65	13,526.58	4,064.18	1,561.18	7,901.22	00006068 - 4	פרויקט פלאפון	39034	3
	19.61	2,005.38	416.58	158.46	1,430.35	00006068 - 5			





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
			00006068 - 6	1,872.98	173.59	400.35	2,446.92	11.79	
			00006366 - 2	2,168.13	363.30	883.19	3,414.62	14.86	
			00006366 - 3	2,277.52	532.65	1,266.08	4,076.25	15.69	
			00006366 - 4	5,843.17	1,010.35	2,607.10	9,460.62	59.35	
			00006366 - 6	1,895.15	186.80	522.59	2,604.54	16.11	
			00021940 - 6	239.94	97.34	233.56	570.83	2.89	
			00021940 - 7	340.87	86.24	199.88	626.99	9.75	
			00021940 - 8	63.65	3.53	11.97	79.15	0.52	
			00022129 - 4	174.23	43.09	98.06	315.37	0.87	
			00022129 - 5	233.97	57.45	113.43	404.85	1.07	
			00022129 - 6	192.21	38.09	61.69	291.98	1.00	
			00022129 - 7	78.15	10.73	5.68	94.56	0.48	
			00022129 - 8	59.42	2.15	2.66	64.23	0.52	
			00022139 - 6	887.09	315.56	810.60	2,013.24	4.78	
			00022585 - 1	215.58	57.39	103.43	376.39	1.17	
			00022585 - 2	174.46	41.89	94.66	311.00	0.89	
			00022585 - 3	83.15	12.84	12.56	108.54	0.45	
			00022585 - 4	255.63	54.88	144.34	454.86	10.77	
			17312760 - 1	491.90	129.00	170.10	791.00	3.41	
			17313253 - 1	7,007.50	2,399.10	6,055.70	15,462.30	33.78	
			סה"כ צריכה	33,886.26	7,335.59	18,278.36	59,500.21		
4	11793	קומה 07 - קיסייט	00006366 - 5	5,425.05	1,113.22	2,272.38	8,810.64	24.66	
			00021940 - 5	3,338.70	412.61	1,085.52	4,836.83	16.23	
			00022129 - 2	381.41	111.54	298.47	791.42	2.82	
			00022129 - 3	3,124.61	1,168.47	2,944.57	7,237.64	11.24	
			00022139 - 2	-316.36	-119.65	-305.99	-741.99	1.07	
			18170708 - 1	380.00	111.20	297.80	789.00	2.81	
			סה"כ צריכה	12,333.41	2,797.39	6,592.74	21,723.54		
			סה"כ צריכה	93,809.03	24,279.17	58,749.17	176,837.37		
			חשבון חברת חשמל				0.00		
			הפרש בקוט"ש				176,837.37		
			הפרש באחוזים						





■ פסגה (Kwh 93,809.03)  
■ גבע (Kwh 24,279.17)  
■ שפל (Kwh 58,749.17)

מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוט"ש	שיא ביקוש	מקדם הספק
1	38173	שנאי 1	00006366 - 8	55,298.11	15,537.73	36,974.14	107,809.98	270.78	
			סה"כ צריכה	55,298.11	15,537.73	36,974.14	107,809.98		
2	38174	שנאי 2	17312726 - 1	36,136.00	8,862.40	21,204.80	66,203.20	465.60	
			סה"כ צריכה	36,136.00	8,862.40	21,204.80	66,203.20		

