



דוח קוט"ש

עבור: הון ניהול

דוח מסכם עבור: פארק הייטק רעננה בניין E

תקופת דוח: (01/06/22 - 30/06/22)

תאריך הפקה: 05/07/22

מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
		15,616.34	6,424.45	2,752.94	6,438.96	80003223 - 6	ARM UPS - חדר חשמל ראשי בחניון	28618	1
		15,616.34	6,424.45	2,752.94	6,438.96	סה"כ צריכה			
		1.44	0.67	0.25	0.52	80002031 - 3	ARM קומה 2	27969	2
		1,072.38	362.50	166.78	543.10	80003223 - 2			
		1,073.82	363.17	167.03	543.62	סה"כ צריכה			
		1.39	0.60	0.23	0.56	80002031 - 4	ARM קומה 3	27966	3
	10.40	2,854.40	496.80	361.60	1,996.00	80003257 - 7			
	17.20	8,163.80	2,412.10	1,347.20	4,404.50	81017159 - 4			
		11,019.59	2,909.50	1,709.03	6,401.06	סה"כ צריכה			
		712.85	270.56	107.17	335.12	80002031 - 5	ARM קומה 4	27970	4
	16.80	3,773.60	624.80	331.20	2,817.60	80003224 - 7			
		4,486.45	895.36	438.37	3,152.72	סה"כ צריכה			
	15.20	2,980.80	488.00	242.40	2,250.40	80001690 - 3	ARM קומה 7	27968	5
		396.63	156.18	60.86	179.59	80002031 - 8			
	11.10	3,274.40	980.30	435.10	1,859.00	81017159 - 8			
		6,651.83	1,624.48	738.36	4,288.99	סה"כ צריכה			
		0.00	0.00	0.00	0.00	15091250 - 1	NICE	13026	6
	0.31	114.29	73.73	19.98	20.58	15091250 - 2			
	0.04	0.00	0.00	0.00	0.00	16092121 - 1			
	8.80	1,754.40	318.40	158.40	1,277.60	80001690 - 6			
		20.18	8.24	3.74	8.20	80001767 - 2			
		296.48	11.59	3.41	281.48	80001767 - 4			
		0.00	0.00	0.00	0.00	80001767 - 5			
	3.20	271.20	100.80	51.20	119.20	80003224 - 4			
	1.05	149.60	62.00	26.60	61.00	80003257 - 5			
		2,606.15	574.76	263.33	1,768.06	סה"כ צריכה			
	1.31	136.52	1.46	5.00	130.06	15091162 - 1	ORCA קומה 5	13028	7
	0.17	1.64	0.00	0.00	1.64	15091162 - 3			
	1.47	96.68	0.12	0.10	96.47	15091162 - 4			
	65.88	60.63	13.47	5.36	41.80	16048009 - 1			
	1.05	136.15	0.36	3.93	131.86	16048009 - 2			
		431.63	15.41	14.39	401.83	סה"כ צריכה			





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטי"ש	שיא ביקוש	מקדם הספק
8	13017	ORCA קומה 6	16092121 - 3	1,069.69	419.56	1,062.76	2,552.01	4.65	
			16092121 - 4	3,430.54	1,343.32	3,393.20	8,167.07	15.68	
			80001690 - 2	1,348.00	164.80	278.40	1,791.20	13.60	
			80002031 - 7	588.19	219.30	506.57	1,314.05		
			81017159 - 7	1,004.90	180.10	219.50	1,404.50	5.50	
			סה"כ צריכה	7,441.32	2,327.08	5,460.44	15,228.83		
9	25873	אלביט מערכות תקשוב וסייבר	16092121 - 2	1.97	1.37	3.06	6.40		
			80001690 - 4	0.00	0.00	0.00	0.00		
			80001976 - 1	0.67	0.29	0.68	1.65		
			80001976 - 2	1.14	0.50	1.16	2.80		
			80001976 - 5	0.09	0.00	0.04	0.13		
			80001976 - 6	0.00	0.00	0.00	0.00		
			סה"כ צריכה	3.87	2.16	4.95	10.97		
10	34774	ניס מעבדה ראשית שנאי 3	0333 - 1	0.00	0.00	0.00	0.00		
			סה"כ צריכה	0.00	0.00	0.00	0.00		
11	13021	סייברביט	80002031 - 2	106.27	47.53	113.18	266.98		
			80003217 - 7	0.00	0.00	0.00	0.00		
			80003271 - 4	92.10	32.30	75.10	199.50		
			סה"כ צריכה	198.37	79.83	188.28	466.48		
12	13016	ציבורי	15091162 - 1	-130.06	-5.00	-1.46	-136.52	1.31	
			15091162 - 3	-1.64	0.00	0.00	-1.64	0.17	
			15091162 - 4	-96.47	-0.10	-0.12	-96.68	1.47	
			15091249 - 1	81.02	26.68	56.58	164.28	1.35	
			15091249 - 2	75.88	24.68	52.31	152.87	1.29	
			15091249 - 3	116.25	40.84	92.99	250.08	1.34	
			15091249 - 7	410.51	156.47	378.95	945.93	1.51	
			15091249 - 8	0.00	0.00	0.00	0.00		
			15091249 - 9	0.00	0.00	0.00	0.00		
			- 10 15091249	0.00	0.00	0.00	0.00		
			- 11 15091249	0.00	0.00	0.00	0.00		
			- 12 15091249	0.00	0.00	0.00	0.00		
			15091250 - 3	0.00	0.00	0.00	0.00		
			15091250 - 4	0.00	0.00	0.00	0.00		
			15091250 - 5	0.00	0.00	0.00	0.00		
			15091250 - 7	0.00	0.00	0.00	0.00		






מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטי"ש	שיא ביקוש	מקדם הספק
			15091250 - 8	0.00	0.00	0.00	0.00		
			15091250 - 9	0.00	0.00	0.00	0.00		
			- 10 15091250	0.00	0.00	0.00	0.00		
			- 11 15091250	0.00	0.00	0.00	0.00		
			- 12 15091250	0.00	0.00	0.00	0.00		
			16048009 - 1	-41.80	-5.36	-13.47	-60.63	65.88	
			16048009 - 2	-131.86	-3.93	-0.36	-136.15	1.05	
			16092120 - 2	0.00	0.00	0.00	0.00		
			16092120 - 3	0.00	0.00	0.00	0.00		
			16092120 - 4	0.00	0.00	0.00	0.00		
			80001690 - 1	228.80	68.00	158.40	455.20	121.60	
			80001690 - 5	640.80	108.80	348.00	1,097.60	16.80	
			80001767 - 1	632.10	101.74	338.02	1,071.86		
			80001767 - 2	-8.20	-3.74	-8.24	-20.18		
			80001767 - 3	351.48	99.74	331.01	782.23		
			80001767 - 4	-281.48	-3.41	-11.59	-296.48		
			80001767 - 5	0.00	0.00	0.00	0.00		
			80001976 - 7	0.21	0.02	0.11	0.33		
			80001976 - 8	4.27	1.86	4.34	10.47		
			80002031 - 1	186.74	82.01	191.55	460.30		
			80003217 - 1	2.46	1.08	2.51	6.05		
			80003217 - 2	2.51	1.10	2.56	6.17		
			80003223 - 4	14,608.19	7,120.90	14,114.38	35,843.46		
			80003224 - 3	0.00	0.00	0.00	0.00		
			80003224 - 6	212.00	92.00	216.00	520.00	0.80	
			80003257 - 2	784.00	172.60	112.00	1,068.60	3.80	
			80003257 - 3	2.80	1.20	3.00	7.00		
			80003257 - 4	11,074.40	2,343.20	1,236.00	14,653.60	60.80	
			80003257 - 6	109.60	47.40	110.20	267.20	0.40	
			80003257 - 8	24,773.60	1,380.80	180.00	26,334.40	249.60	
			80003271 - 2	799.40	169.20	379.20	1,347.80		
			80003271 - 3	26.45	3.80	9.00	39.25		
			80003271 - 5	254.40	71.70	163.00	489.10		
			80003271 - 6	2,548.20	1,190.90	2,508.40	6,247.50		
			80003271 - 7	1,066.00	382.60	789.20	2,237.80		
			80003271 - 8	0.00	0.00	0.00	0.00		





מקדם הספק	שיא ביקוש	סה"כ צריכה בקוט"ש	שפל Kwh	גבע Kwh	פסגה Kwh	מספר מונה / קבוצה	שם דייר	מזהה דייר	מס
	2.20	878.50	326.50	152.30	399.70	81017159 - 1			
	3.70	2,204.70	910.20	390.90	903.60	81017159 - 2			
		96,793.97	22,979.15	14,210.96	59,603.86	סה"כ צריכה			
	1.12	510.54	210.68	84.94	214.93	16092120 - 1	קומה 8 סייברביט	25872	13
		1,450.34	600.62	257.93	591.79	80001976 - 3			
		350.36	145.26	62.32	142.78	80001976 - 4			
		18,057.80	7,475.00	3,205.47	7,377.34	80003217 - 6			
	14.40	3,892.00	976.00	452.80	2,463.20	80003224 - 5			
		2,246.00	790.30	353.20	1,102.50	80003271 - 1			
		26,507.04	10,197.85	4,416.66	11,892.54	סה"כ צריכה			
	1.31	-136.52	-1.46	-5.00	-130.06	15091162 - 1	תדהר	13027	14
	0.17	-1.64	0.00	0.00	-1.64	15091162 - 3			
	1.47	-96.68	-0.12	-0.10	-96.47	15091162 - 4			
	65.88	-60.63	-13.47	-5.36	-41.80	16048009 - 1			
	1.05	-136.15	-0.36	-3.93	-131.86	16048009 - 2			
	4.65	638.00	265.69	104.89	267.42	16092121 - 3			
	15.68	2,041.77	848.30	335.83	857.64	16092121 - 4			
		118.47	29.68	13.35	75.44	80002031 - 6			
	5.60	454.40	61.60	31.20	361.60	80003224 - 8			
	3.50	531.50	68.60	45.50	417.40	81017159 - 6			
		3,352.51	1,258.46	516.38	1,577.66	סה"כ צריכה			
		184,245.63	52,896.25	27,636.52	103,712.86	סה"כ צריכה			
		0.00				חשבון חברת חשמל			
		184,245.63				הפרש בקוט"ש			
						הפרש באחוזים			



■ פסגה (103,712.86 Kwh)
■ גבע (27,636.52 Kwh)
■ שפל (52,896.25 Kwh)





מס	מזהה דייר	שם דייר	מספר מונה / קבוצה	פסגה Kwh	גבע Kwh	שפל Kwh	סה"כ צריכה בקוטר"ש	שיא ביקוש	מקדם הספק
1	12425	מפסק ראשי שדה חיוני	80003223 - 1	48,755.65	19,594.56	41,723.62	110,073.82		
			סה"כ צריכה	48,755.65	19,594.56	41,723.62	110,073.82		
2	12421	צילר 4 על הגג- ציבורי מדידה של נייס משלמים לחח"י	80003224 - 2	26,180.80	9,347.20	22,107.20	57,635.20	200.80	
			סה"כ צריכה	26,180.80	9,347.20	22,107.20	57,635.20		
3	12427	ראשי שנאי AT1	80003257 - 1	43,974.40	5,075.20	3,814.40	52,864.00	313.60	
			סה"כ צריכה	43,974.40	5,075.20	3,814.40	52,864.00		
4	12428	ראשי שנאי AT2	80003224 - 1	56,083.20	20,960.00	44,608.00	121,651.20	294.40	
			סה"כ צריכה	56,083.20	20,960.00	44,608.00	121,651.20		

